Performance Analysis of VRLA Battery for DC Load at Telecommunication Base Station

Imelda Uli Vistalina Simanjuntak^{1*)}, Heryanto²⁾, Yossy Rahmawaty³⁾, and Tulus Manurung⁴⁾

^{1,3,4)} Department of Electrical Engineering, Mercu Buana University, Indonesia

²⁾ Department of Electrical Engineering, Indonesia Defense University, Indonesia

Corresponding Email: ^{*)}imelda.simanjuntak@mercubuana.ac.id

Abstract –The high level of power outage in Sukabumi-Cianjur area has influenced the operations of telecommunication industry in the vicinity. This has shortened the battery life at the Base Station (BTS). This study aims to analyze the performance of a (new) VRLA battery against a DC load (BTS) to support the continuity of BTS operation in case of a power outage. The research method used is a (new) battery charge-discharge procedure. Parameters are analyzed by determining the on-site battery discharge duration, the pressure at the battery terminals between cells during backup, and the capacity of the rectifier module to support fast charging. To support fast charging, the rectifier with the formula $N+1$ and C-rate is 10% and C15 is 15% of the battery capacity. The internal impedance value is 3.4 mΩ and the battery terminal pressure (torque) is 9-11 N/m. The battery performance analysis of the four BTS shows that two of them managed to do a backup, while the other two did not provide good performance.

Keywords: charge-discharge, C-rate, rectifier, torque, VRLA battery

I. INTRODUCTION

Competition among telecommunication operators always demands excellent service for the customers. Therefore, most devices must be on standby 24 hours. The frequent power outage in Sukabumi-Cianjur area has influenced the operations of telecommunication industry. In the BTS shelter, there is a VRLA battery as backup power in case of power outage. This type of battery is very susceptible to high temperature caused by unstable electricity which can shorten its life.

Previous research aims to determine the energy efficiency of the lead acid battery through the charging process with the constant current method of 0.3 A, 0.5 A, and 0.6 A. Based on the test results of the charge-discharge process, the current variation of 0.3 A, 0.5 A, and 0.6 A results in energy efficiency of 76.32%, 76.06% and 91.33%, respectively[1].

A study shows that charging times can be reduced by using fuzzy logic or model prediction controls. This paper reviews the existing methods to control the charging and discharging processes, focusing on their impact on battery life [2].

A research compared some aspects between lead-acid batteries and lithium-ion batteries, the two main options for stationary energy storage. Various properties and characteristics are summarized specifically for valve regulated lead acid batteries (VRLA) and lithium iron

phosphate (LFP) lithium-ion batteries. The charging process, efficiency, and life cycle are discussed for each battery type. Through a specific cost analysis, lithium-ion batteries have been proven to be a cost-effective alternative [3].

Table 1. Differences with some reference journals

No.	Title	Comparative Journal	Description
1	The Effect of Current Variations Charge discharge of Lead Acid Battery for Energy Efficiency	battery charging method, with different C-rate	Volume 16, No 1, Februari 2019 ISSN:1829-796 (print); 2541-1713 (online)
2	A Review on Battery Charging and Discharging Control Strategies: Application to Renewable Energy Systems	battery charging method	Energies 2018, 11, 1021; DOI:10.3390/en11041021
3	Comparison of Lead-Acid and Lithium-Ion Batteries for Stationary Storage in Off-Grid Energy Systems	Difference of battery types and on grid and off grid implementation	IEEE - Institute of Electrical and Electronics Engineers Inc. ISBN: 978-1-78561-238-1 DOI: 10.1049/cp.2016.1287
4	Performance Analysis of VRLA Battery for DC Load at Telecommunication Base Station	Battery checking and re-measurement, charging of new batteries	Proposed

Based on some of the references above, this study analyzes the performance of the VRLA battery which influences the battery life so that premature replacement does not occur frequently. By charging and discharging the new battery, and predicting the battery life, simulation can be maximized.

Figure 1. Research venn diagram

This study refers to three previous studies. The first reference [1] is charging analysis based on C-rate (capacity) where only 2 types of C-rate are used. The second reference [2] is the analysis of the charging methods used, i.e., the equalize and floating method. And the third reference [3] is the application of a battery that is charging and releasing energy (discharging) on the grid.

II. METHODOLOGY

A. Definition of VRLA Battery

A VRLA (valve-regulated lead-acid) battery is a battery with electrodes made of lead immersed in dilute sulfuric acid [4]. This battery is often called as dry batteries because of the shape and design, it can be installed in any position and do not require constant maintenance compared to wet batteries. However, the term “maintenance free” is also incorrect because the VRLA battery needs to be cleaned and undergo functional testing regularly. This type of battery is widely used in large portable electrical devices, off-grid power systems (not connected to the PLN electricity network) and others. VRLA batteries are very susceptible to high temperature as it can cause damage to battery cells [5].

B. Battery Construction

The battery structure is explained as follows.

a) Positive and negative plates

The positive and negative plates consist of the active mass and network structure of the tin-calcium alloy.

b) Separator

Non-woven glass fiber fabric with high oxidation and heat resistance offers superior electrolyte absorption and satisfactory ion retention and conductivity.

c) Electrolyte

Dilute sulfuric acid is used as a medium for conducting ions in electrochemical reactions in batteries

d) Safety valve

The safety valve opens when there is an abnormal increase in internal pressure caused by overfilling or misuse. Gas

is released from the battery to bring the pressure back to normal.

e) Container and cover

The container and cover are made of ABS or PP resin, with superior strength and acid resistance characteristics. The container and lid are sealed to prevent electrolyte and gas leakage.

f) The positive and negative electrode terminals

The positive and negative electrode terminals can be tab fasten, bolt fastening, threaded post, or lead wire type, depending on the battery type. Terminal sealing is achieved by the structure which secures the long sticking adhesive path and by the strong adoption of epoxy adhesive.

Figure 2. Battery Construction [5]

C. Characteristics of Valve Regulated Lead Acid (VRLA) Battery

This battery has no caps/valve, no access to electrolyte, and is totally sealed. Thus, this type of battery does not require maintenance. Deep cycle battery, is a battery that is suitable for solar cell system, because it can discharge a constant amount of electric current for a long time. Generally, deep cycle batteries can discharge up to 80% of the battery capacity. This type of battery can last for approximately 10 years with good capacity planning and maintenance [5].

Table 2. Characteristics of lead acid based on standard[6]

CHARACTERISTICS	LEAD ACID
Specific energy (Wh/kg)	30-50
Internal resistance (mΩ)	very low
Life cycle (80% discharge)	200-300
Fast-charge Time	8-16 hours
0.2Copr C/5	5h
0.1C or c/10	10 h
0.05C or c/20	20 h
Overcharge tolerance	High
Self-discharge/month	5%
Cell voltage (nominal)	2V
Cut-off Charge Voltage (V/cell)	2.40 float 2.25
Cut-off Discharge Voltage (V/cell, IC)	1.75
Load Peak Current	5C
Besat result	0.2C
Charge temperature	-20 up to 50°C
Discharge temperature	-20 up to 50°C
Maintenance	3-6 months

CHARACTERISTICS	LEAD ACID
Safety	stable temperature
Used since	around 1800s

D. Battery Charging

According to Wasith dany mufty [7], there are several methods for charging batteries such as Constant Trickle (CTC), Constant Current (CC), Constant Voltage (CV), and Constant Current Constant Voltage (CC CV). Constant Current is a method of charging the battery with a constant current until the battery capacity is full. While Constant Voltage is charging the battery with a constant voltage until the battery capacity is full, more details can be seen in Figure 3 [8].

Figure 3. Characteristics of CVC (Constant Voltage Charge)

In CV (constant voltage) method, there are three stages for wet and dry batteries, i.e., absorption, equalizing, and float (trickle voltage) [9]:

1) Floating Charge, the stage of charging the battery with a constant voltage (2.23 V/cell) without time limit to keep the battery full.

2) Equalizing Charge, a battery charging stage to equalize the voltage on each battery cell due to the voltage difference, by providing an overvoltage (2.35 V/cell), but not greater than the boosting voltage.

3) Boosting Charge, is a fast-charging process carried out after the capacity test. This process is intended to charge the empty battery after the capacity test.

Acid density will vary according to temperature and state of battery charge [10]. Lead acid batteries work based on reduction and oxidation reactions of the anode and cathode materials. When the battery discharges, the active material on the electrodes reacts with the electrolyte to form PbSO_4 and water, and vice versa. The basic cell reaction in a lead acid battery is described as follows:

Reaction on battery charging:

During the charging process, the following reactions occur [10]:

a) At the negative electrode (anode):

b) At the positive electrode (cathode):

E. Battery Discharging

The battery capacity is 170 Ampere hour which means that the battery current will run out in one hour, when the load uses 170 Ampere. The recommended battery discharge level is up to 1.70 Volts per cell. The battery will be damaged if the voltage per cell is less than 1.70 Volts (or 10 Volts for 12 Volt batteries). Battery life is calculated in cycles where one cycle means one time of usage and charging. Depth of discharge (amount of battery amperage usage) affects the number of battery cycles. At 25 degrees Celsius, there are 150-200 cycles with 100 percent depth of discharge (full discharge), 400-500 cycles with 50 percent depth of discharge (partial discharge), and 1000 cycles or more with 30 percent depth of discharge (shallow discharge).

The following are the chemical reactions during discharging according in the research [10]:

a) Reaction at the negative electrode (anode):

b) At the positive electrode (cathode):

F. Rate (C-Rate)

The rate of battery charge and discharge is set by the C-Rate. Battery capacity is generally rated at 1C, which means that a fully charged battery rated at 1Ah should provide 1A for an hour. The same battery discharge at 0.5C should give 500mA for two hours, and at 2C it should give 2A for 30 minutes. Loss on fast discharge reduces discharge time and this loss also affects charging time.

Table 3. Comparison of C-Rate against duration

C-RATE	TIME
5C	12 min
2C	30 min
1C	1 h
0.5C or C/2	2h
0.2C or C/5	5h
0.1C or C/10	10 h
0.05C or C/20	20 h

Table 3 illustrates typical times at various C-levels. C-rate 1C is also known as one hour discharge; 0.5C or C/2 is a two-hour discharge and 0.2C or C/5 is a 5-hour discharge. Some high-performance batteries can be charged and discharged above 1C with moderate pressure.

G. Rectifier

Rectifier is a circuit system to convert AC into DC current. On site load requires a DC supply which are entirely taken from the rectifier, such as BTS, lighting in BTS, transmission, and so on. Inside the rectifier rack, there is a module to convert AC into DC current. Apart from being a current rectifier, this module also charges the battery. In principle, the rectifier will supply the power

needed by the BTS in a fully loaded condition while maintaining the battery charge.

The battery characteristics also need to be considered in regulating the current when charging, because if a battery is recharged with a current exceeding the battery capacity limit, it can shorten the life of the battery. The charging current for a back-up battery is usually 80% of the current condition issued by the battery at full load (in an emergency or back-up condition where the electricity supply from PLN is interrupted).

Figure 4. Indoor (left) and outdoor (right) DC rectifier for telecommunication base station

H. SOP Planning Block Diagram

Figure 5. Block diagram of performance analysis of (new) type VRLA battery system design

Block diagram of performance analysis of VRLA battery system design against DC (BTS) load in Cianjur cluster is created by preparing SOP of battery charge-discharge process. The next stage is the charge-discharge step, followed by delivery-MOS, and the final phase is monitoring and evaluation.

I. Data collection

Data collection on the Battery Charge-Discharge process is shown in Figure 6 and the explanation of the parameters can be seen in Table 2.

Figure 6. Data collection block diagram

J. Data collection on Battery Charge-Discharge Process

Testing of the battery charge-discharge system is carried out by assessing hardware components. Components tested include equalize charge, discharge, floating charge, internal impedance, and C-rate on the size of the rectifier module.

K. Data collection from the Installation and Commissioning Process

System testing is testing the battery installation on the rectifier rack and commissioning the battery parameters on the rectifier controller which includes, voltage, current, temperature, LLVD, BLVD, C-rate charge-discharge battery shown on figure 7.

Battery type									
Quantity				Block					
Charging method				Celcius				SOC 100%	
Checking method				Equalize/BoostFlo					
Temperature				MIL-STD					
Batt No Battery	Serial Number	T_0	T_1	T_2	T_3	T_4			
		0:00	0:30	1:00	1:30	2:00			
		16:00	16:30	17:00	17:30	18:00			
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
	Total Voltage								
	Total Load								
	Avg- max								
	min								
	avg+								
	avg std								

Figure 7. Battery Charge–Discharge form

L. Data Analysis

The analyzed data are battery charge-discharge; data and graph of equalize charge, discharge, and floating charge; internal impedance; and C-rate of the rectifier module as follows:

- Initial charge.
- Equalize charge, the stage of charging the battery to equalize the voltage on each battery cell.
- Discharging, the process of emptying the battery capacity against a constant load.
- Floating charge, the stage of charging the battery with a constant voltage (2.23 V/cell) without time limit to keep the battery full.
- Internal resistance, resistance against the flow of current in the battery.
- C-rate of the rectifier module. To charge the battery at a certain C-rate, a large rectifier capacity (as a current charger) is required according to the C-rate.

III. RESULTS AND DISCUSSION

A. Charging process analysis

The duration of charging time is influenced by the amount of charging current. The duration required for the battery charging process is indicated in Table 4.

Table 4. Technical data on battery conditions and load from a sample of four cluster sites in Sukabumi Cianjur

	Initial Charge	Equalize Charge	Floating Charge	Boosting Charge
Constant Current	10.2A	13.6A	17A	17A
Duration	20 H	15 H	12 H	8 H

Table 4 shows the battery capacity generated during the charging process. When the charging current is greater, the stored battery capacity will also increase because when charging the charges will flow into the battery.

B. Discharge process analysis (under constant load conditions)

Table 5 summarizes the discharge duration of a battery with capacity and current of 2×170 Ah and 68 A, respectively. The battery ability to provide backup power when the main voltage source is interrupted is defined as:

$$C = I \times t, t = C / I \gg (2 \times 170) / 68 = 5 \text{ Hours}$$

This means that the Shoto 6FMX170 battery as a backup power source at a load of 68A can last approximately five hours.

Table 5. Test of battery capacity on discharge

Battery Bank	Discharge Time						
	0M	40M	80M	120M	160M	200M	240M
B1-2	50.2	50.0	49.4	48.8	48.2	47.3	46.5
B3-4	50.2	50.1	49.4	48.9	48.2	47.3	46.6
B5-6	50.3	50.1	49.4	48.9	48.2	47.4	46.6
B7-8	50.3	50.1	49.5	48.9	48.3	47.4	46.6
B9-10	50.2	50.1	49.4	48.9	48.2	47.3	46.6

C. Battery discharge process in actual conditions on site

The battery discharge process in the field uses the VRLA Shoto 6FMX170 type. The technical specifications of the battery are a nominal voltage of 12V and a nominal capacity of 170 Ah @ 10 Hr up to 1.8V/cell.

The battery is connected in series 43.2 Volt DC and the battery is connected in parallel 340 Ah C10. The final capacity formed is 43 Volt/340 Ah C10. The calculation result of the battery in supplying backup power is shown in Table 6.

Table 6. Technical data on battery conditions and load from a sample of four cluster sites in Sukabumi Cianjur

Site ID	Site Name	Bank Qty	Total Battery Capacity (Ah)	Rectifier Load, I (A)	Backup Time Battery $T = C/I$ (hours)
03SMD045	JATI NUNGGAL	1	170 C10	28	6.1
03SUK079	MEKAR SARI	2	340 C10	53.9	6.3
03SUK207	SUKAMAJU SMI	2	340 C10	65.3	5.2
03CJR210	PASIR BITUNG_TB	2	340 C10	33	10.3

D. Process battery discharge when PLN off

Table 7. Technical data on battery conditions and load from a sample of four cluster sites in Sukabumi Cianjur

Site	Backup Duration	Battery Voltage	Backup Energy Supply (24 cell)	Battery performance
Jatinunggal	4 H	47.7 VDC	1.98 V/cell	Good
Mekarsari	4 H	46.2 VDC	1.92 V/cell	Good
Sukamaju jaya_Smi	2H	42 VDC	1.75 V/cell	Not Good
Pasir bitung_Tb	4 H	44.7 VDC	1.86 V/cell	Not Good

After the charge-discharge process was carried out on the new VRLA battery and tested on site, it was found that the condition of the batteries in two locations did not provide good performance as shown on Table 7. This might be due to the lock moment on the battery bolt is too tight or even too loose which results in a decrease in the supply ability of the battery.

E. Analysis of Inter-cell battery bolt torque

A torque wrench is a tool to turn bolts and nuts on a tool with a certain level of tightness. This is important, because inaccurate and unmeasured torque measurements such as when using hands, or an ordinary wrench can be fatal for the device. For example, in the installation of bolts and nuts on a battery that will experience heating from the chemical reaction of the battery, the reaction will cause uneven expansion of the surface or rods of bolts and nuts. So, if the lock is too tight or too loose it can cause a decrease in the battery supply capability.

The magnitude of the torque value is determined by the type, size, and also the grade of the bolt material. For the 170AH VRLA battery, the terminal specifications of the M6 battery are equivalent to $d=0.236m$. then the force required to tighten the battery nut with a torque of 9-11 Nm is:

$$\begin{aligned}
 T &= F \times r \\
 F &= \frac{T}{r} \\
 F &= \frac{10}{0.236} \\
 &= 84,74 \text{ N}
 \end{aligned}$$

F. Analysis of the effect of rectifier module quantity on the battery charge-discharge process.

Then the next analysis is how many rectifiers are required according to the load on site. Rectifier is a device to convert alternating current (AC) into direct current (DC) sources. From this research, three types of rectifier samples in the Sukabumi Cianjur cluster are as follows:

- 1) Huawei R4850G1 rectifier module
- 2) Delta DPR2900 rectifier module
- 3) Eltek FP3000 rectifier module

Table 8. Capacity analysis of Rectifier

	Analysis of Rectifier Capacity		
	Huawei R4850G1 Module	Eltek FP2-3000 Module	Delta DPR2900 Module
Rated load	56 A	62.5 A	56.25 A
Rectifier output	53.5 VDC	53.5 VDC	54 VDC
Total load	168 A	187.5 A	168.5 A
Floating voltage	53.5 VDC	53.5 VDC	54 VDC
Boost voltage	56.4 VDC	56.4 VDC	57.8 VDC
P _{Used}	1765.5 W	2883.7 W	3526.2 W
P _{available}	9000 W	10031.3 W	9112.5 W
Utilization	18.8 %	28.7 %	38.6 %
Rectifier modules	2	2	2
Peak load (Kc)	84 A	104.9 A	116.2 A
Module requirements	2	2	3

The need for the rectifier is adjusted to the type of module as listed in Table 8.

IV. CONCLUSION

Based on the results of mathematical calculations and then testing in the field, the analysis showed that the condition of the battery that had been carried out in the charge discharge process on the new VRLA battery was then installed at the site on the condition that the AC PLN source was off, only two sites, i.e., Jatinunggal and Mekarsari, which could provide good performance. Sukamaju and Pasir Bitung sites did not provide good performance which might be due to an inappropriate key moment when charging the battery and the number of rectifiers required is adjusted to the type of module and the load of the BTS on site.

The charge-discharge process for a (new) battery is highly recommended, so that the battery is ready to be used for unstable electricity supply by using the C10 and C15 C-rate of the battery capacity to support the fast-charging process.

REFERENCES

- [1] M. Y. Kurriawan Budi Pranata, Muhammad Priyono Tri Sulistyanto, Muhammad Ghufro, "Pengaruh variasi arus pengisian pengosongan muatan pada model baterai lead acid terhadap perubahan efisiensi energi," *J. Fis. Flux*, Vol. 16, No. 1, Hal. 1–6, 2019.
- [2] A. A. Edison Banguero, Antonio Correcher, Ángel Pérez-Navarro, Francisco Morant, "A review on battery charging and discharging control strategies: application to renewable energy systems edison," *Energies* 2018, Vol. 11, No. 1, Hal. 1–15, 2018, Doi: 10.3390/En11041021.
- [3] T. S. U. Hardik Keshan, Jesse Thornburg, "Comparison of lead-acid and lithium ion batteries for stationary storage in off-grid energy systems," In *4th Iet Clean Energy And Technology Conference (Ceat 2016)*, 2016, Hal. 1–7, Doi: 10.1049/Cp.2016.1287.

- [4] Yuliza Dan Ardiansyah, "Perancangan lampu taman solarcell otomatis untuk menggunakan microcontroller arduino uno," *J. Tek. Elektro Univ. Mercu Buana*, Vol. 7, No. 1, Hal. 37–44, 2016.
- [5] W. A. Pandyapratita Putra, Andrew Joewono, Rasional Sitepu, Lanny Agustine, "Alat pemantau dan pengendali sistem penyimpanan energi pada solar panel," *Sci. J. Widya Tek.*, Vol. 17, No. 1, Hal. 25–31, 2018.
- [6] A. F. Farizy, "Desain sistem monitoring state of charge baterai pada charging station mobil listrik berbasis fuzzy logic dengan mempertimbangkan temperature design of monitoring system of state of charge of battery in a charging station electric car based on fuzzy logic," 2016.
- [7] M. Z. E. Wasith Dany Mufty, Dimas Okky Anggriawan, "Baterai charger vrla dengan metode constant current constant voltage berbasis kontrol pi," In *Seminar Nasional Terapan Riset Inovatif (Sentrinov) Ke-6*, 2020, Vol. 6, No. 1, Hal. 235–243.
- [8] Chinashoto.Com V2.0, "6-Fmx Series Front Terminal Battery 6-Fmx-170 Dimensions : ," *Chinashoto*. 2011.
- [9] N. Ricky Agned, "Studi kapasitas baterai 110 vdc pada gardu induk 150 kv bangkinang," *Jom Fteknik*, Vol. 3, No. 2, Hal. 1–9, 2016.
- [10] R. D. Barkah Dan S. Hidayat, "Simulasi charge discharge model baterai lead acid," *Jiif (Jurnal Ilmu Dan Inov. Fis.*, Vol. 03, No. 02, Hal. 128–134, 2019.